NOTIFICATION.

(LAW DEPARTMENT).

No. LAW 79 LCR 63, dated Bangalore, the 5th February 1963.

Ordered that the accompanying Notification No. G.S.R. 38, dated the 19th December 1962, of the Ministry of Works Housing and Rehabilitation, amending the Indian Boiler Regulations, 1950 which has been published in the *Gazette of India*, Part II, Section 3, sub-section (i), dated the 5th January 1963, be republished in the *Mysore Gazette*, for general information.

By Order and in the name of the Governor of Mysore,

304

S. SRIPADARAJ,
Under Secy. to Govt., L. D

GOVERNMENT OF INDIA.

MINISTRY OF WORKS, HOUSING AND REHABILITATION

(Department of W. and H.)

(Central Boilers Board)

New Delhi, the 19th December 1962.

G.S.R. 38.—In exercise of the powers conferred by section 28 of the Indian Boilers Act, 1923 (5 of 1923), the Central Boilers Board hereby makes the following Regulations further to amend the Indian Boiler Regulations, 1950, the same having been previously published as required by sub-section (1) of section 31 of the said Act, namely:—

1. These Regulations may be called the Indian Boiler (Twenty-seventh Amendment) Regulations, 1962.

2. In the Indian Boiler Regulations, 1950, for clauses (a) and (b) of Regulation 382, the following clauses shall be substituted, namely :—

382. **Engraving of registry number* :

"(a) The registry number of every boiler shall, within a period of one month from the date of receipt thereof be cut in the front plate or any such position as shall be pointed out by the Inspector. The device

for each State Union Territory shall be distinguished by the following letters :—

Andaman and Nicobar Islands	...	A&N
Andhra Pradesh	...	AP
Assam	...	A
Bihar	...	BR
Delhi	...	D
Gujarat	...	GT
Himachal Pradesh	...	HP
Kerala	...	K
Laccadive, Minicoy & Amindiv Islands	...	LI
Madhya Pradesh	...	MP
Madras	...	M
Maharashtra	...	MR
Manipur	...	MA
Mysore	...	MYS
Orissa	...	OR
Punjab	...	PI
Rajasthan	...	RJ
Tripura	...	TR
Uttar Pradesh	...	UP
West Bengal	...	WBL

The distinguishing letters shall be engraved above a number and separated therefrom by a horizontal line 64 mm. (two and a half inches) in length. The letters and figures shall be 25 mm. (one inch) in height and of suitable breadth, provided that in the case of small boilers the letters and figures of the device may, in the discretion of the Chief Inspector, be reduced to 10 mm. (3/8") in height. The whole shall be enclosed in a rectangle, the upper and lower sides of which shall be 76 mm. (three inches) apart and 6 mm. (one quarter inch) clear of the top of the letters and the bottom of the figures respectively as indicated below :—

MR
1234

The side lines shall be at equal distance clear from the figures. The engraving shall not be less than 0·4 mm. (1/64 inch) in depth.

(b) The engraving shall be complete and ready for verification within one month from the date of receipt of registry number, and the fact shall be reported to the Chief Inspector of Boilers within this period."

[No. S&PII/BL-9(63)/61].

S. N. SEN GUPTA, Secy.